



SISTEMUL HIDROTEHNIC VOILA - LABORATOR CALITATEA APEI VOILA

Sos.Paltinului nr.19, Campina Tel. 0769074796

Laborator inreg. la Ministerul Sanatatii pentru monitorizarea calitatii apei potabile conf. Legii 458/2002

RAPORT DE INCERCARE NR: 1187/ DATA: 17.08.2021

BENEFICIAR.....

PROBA DE ANALIZAT - apa potabila clorinata

Prelevare: - punct de prelevare - lesire rezervoare apa potabila fir1, STA VOILA

- metoda de prelevare -SR ISO 5667-5/2017; SR EN ISO 19458/2007

- prelevatorul -Laborator Calitatea Apei Voila

Data prelevarii probei:17.08.2021

Data executarii analizei: 17.08.2021

NOTE:

1.Acest buletin de analiza se refera numai la proba de apa specificata.


2.Se interzice reproducerea totala sau partiala a acestui raport de incercare fara aprobarea emitentului


NR. CRT	DENUMIREA ANALIZEI	METODA DE ANALIZA	LIMITE ADM. CF. LEGII 458/2002 republicata	REZULTAT
1	Turbiditate (NTU)	SR EN ISO 7027-1/2016	5	0,403
2	Culoare (m ⁻¹)	SR ISO 7887/2012	nicio modificare anormala	<0,07
3	Gust TFN	SR EN 1622/ 2007	nicio modificare anormala	FARA
4	Miros TON	SR EN 1622/ 2007	nicio modificare anormala	FARA
5	Conductivitate (microS/cm)	SR EN 27888/1997	2500	337
6	Clor rezidual liber/total (mg/l)	SR ISO 7393-2/2018	0,1–0,5 in retea	0,74/0,79
7	pH (unitati ph)	SR ISO 10523/2012	6,5-9,5	7,89
8	Duritate (grade germane)	SR ISO 6059/2008	min 5	10,64
9	Cloruri (mg/l)	SR ISO 9297/2001	250	6,3
10	Aluminiu (mg/l)	SR ISO 10566/2001	0,2	0,149






NR. CRT	DENUMIREA ANALIZEI	METODA DE ANALIZA	LIMITE ADM. CF. LEGII 458/2002 republicata	REZULTAT
11	Indice permanganat (mg O ₂ /l)	SR EN ISO 8467/2001	5	<0,5
12	Amoniu (mg/l)	SR ISO 7150/2001	0,5	<0,08
13	Nitriti (mg/l)	SR EN 26777/2002 C 91/2006	0,5	<0,017
14	Nitrati (mg /l)	SR ISO 7890-3/2000	50	2,25
15	Sulfati (mg/l)	STAS 3069-87	250	32
16	Sodiu (mg/l)	electrochimic	200	4,08
17	Mangan (mg/l)	SR ISO 6333/97	0,05	<0,01
18	Carbon organic total (mg/l)	ISO 8245/1999	nicio modificare anormala	1,642
19	Numar de colonii la 22 °C (UFC/ ml)	SR EN ISO 6222/2004	nicio modificare anormala	2
20	Numar de colonii la 37 °C(UFC/ml)	SR EN ISO 6222/2004	nicio modificare anormala	0
21	Bacterii coliforme (numar/100ml)	SR EN ISO 9308-1/2015 A1/2017	0	0
22	Escherichia Coli (numar/100 ml)	SR EN ISO 9308-1/2015 A1/2017	0	0
23	Clostridium perfringens (Specia, inclusiv sporii) (numar/100 ml)	SR EN ISO 14189/2017	0	0
24	Enterococi (numar/100 ml)	SR EN ISO 7899-2/2002	0	0

Intocmit
Responsabil analiza:
Nume: Neacsu
Prenume: Cristina
Semnatura 

Verificat
Responsabil analiza
Nume: Neacsu
Prenume: Cristina
Semnatura 

Aprobat
Sef laborator
Nume: Gologan
Prenume: Daniela
Semnatura 

Buletin de incercare nr 1187 din 17.08.2021

